



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, South 24 Parganas**  
**West Bengal Fire & Emergency Services**  
**6, Diamond Harbour Road, Silpara, Kol-700008**

Memo no.: IND/WB/FES/20192020/58737

Date: 11-02-2022

**From:**

**Divisional Fire Officer, South 24 Parganas**  
**West Bengal Fire & Emergency Services**

**To: Raidighi B.Ed College**

**Vill. and P.O.-Raidighi, P.S.-Raidighi, Dist.-South 24 Parganas, Pin-743383**

**Sub: Fire Safety Certificate for a G+III storied under group Educational Occupancy at the premises No.-Vill. and P.O.-Raidighi, P.S.-Raidighi, Dist.-South 24 Parganas, Pin-743383.**

This is in reference to your application no. 0125189221200009 dated 27-01-2022 regarding the Fire Safety Certificate for a G+III storied under group Educational Occupancy at the premises No.-Vill. and P.O.-Raidighi, P.S.-Raidighi, Dist.-South 24 Parganas, Pin-743383.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. All the fire prevention and fire safety measures shall be maintained in good repair and efficient condition at all times in accordance with the provision of Section 11 C of West Bengal Fire service Act 1950 with up to date amendment.
2. As per submitted declaration the construction of another staircase should be completed within 90(Ninety) days from the date of issue of this certificate failing which this certificate will be treated as cancelled.
3. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
4. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
5. Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
6. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
7. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification.

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189221200009.



10. First aid Fire fighting system shall be provided as per I.S. specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.
12. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
13. Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.
14. This Fire Safety Certificate is valid for 03(three) years from the date of issue of this Certificate.

Digitally signed by  
BIT  
Date: 2022.02.11 13:21:05  
Valid  
Signature

Divisional Fire Officer, South 24 Parganas  
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20192013027